

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Low-voltage fuse-rails

Name and address of the applicant

Mersen France SB SAS
15 Rue Jacques de Vaucanson,
69720 Saint Bonnet de Mure, France

Name and address of the manufacturer

Mersen France SB SAS
15 Rue Jacques de Vaucanson,
69720 Saint Bonnet de Mure, France

Name and address of the factory

Mersen CZ s.r.o.
Pardubická 437,
53304 Sezemice, Czech Republic

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

690 V; 50-60 Hz; 250 A; 3-pole

Trademark (if any)

MERSEN

Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

1.BSL, see also page 7 of test reports.

Additional information (if necessary may also be reported on page 2)

To be used with fuse links NH1 with maximum power dissipation of 32 W. Also found to be in conformity with IEC 60269-1:2006/AMD2:2014.

 Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60269-1:2006
IEC 60269-1:2006/AMD1:2009
IEC 60269-2:2013

As shown in the Test Report Ref. No. which forms part of this Certificate

SGP-05833/1.BSL/CB/1, SGP-05833/1.BSL/CB/2

This CB Test Certificate is issued by the National Certification Body