



Lloyd's  
Register

## Type Approval Certificate Extension

This is to certify that Certificate No. 03/30002E2 for the undernoted products is extended and renumbered as shown.

This certificate is issued to:

<b>PRODUCER</b>	Mersen France SB S.A.S. 15, Rue de Vaucanson 69720 Saint Bonnet de Mure FRANCE	
<b>PLACE OF PRODUCTION</b>	Nolam Tunisia Rue de Nabeul lot no. 4 zone industrielle de M'Ghira TUNISIA	
<b>DESCRIPTION</b>	Fuse holders, 690 V, with or without accessories	
<b>TYPE</b>	CMS 14 – 690 V : 50 A max CMS 22 – 690 V : 125 A max	
<b>APPLICATION</b>	Industrial application for Switch- and Control gear	
<b>RATINGS</b>	CMS 14	CMS 22
Voltage:	690 V	690 V
Fuse:	50 A max	125 A max
Poles:	1 to 4 and N, 1 + N and 3 + N poles	1 to 4 and N, 1 + N 3 + N poles
Category:	AC 20 (IEC 60947-1 or IEC 60947-3)	AC 20 (IEC 60947-1 or IEC 60947-3)
<b>Certificate No.</b>	03/30002 (E3)	
<b>Issue Date</b>	29 April 2014	
<b>Expiry Date</b>	16 March 2019	
<b>Sheet</b>	1 of 2	



Lloyd's  
Register

**ACCESSORIES :** Fuse holders CMS 14 and CMS 22,  
can be equipped with, micro switches and blown fuse indicator.

**STANDARDS :** IEC 60269-1; 2006  
60269-2-1; 2006  
60269-2; 2006  
60947-1; 2007  
60947-3; 2008

**DEGREE OF PROTECTION:** IP 20

*"This Certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid certificate."*

*The attached Design Appraisal Document No ROT.TA.1390326/1 and its supplementary Type Approval Terms and Conditions form part of this Certificate.*

All other details remain as the previous Certificate No. 03/30002 to which this extension should be attached.

**Certificate No.** 03/30002 (E3)  
**Issue Date** 29 April 2014  
**Expiry Date** 16 March 2019  
**Sheet** 2 of 2