

OVE AUSTRIAN ELECTROTECHNICAL ASSOCIATION
Eschenbachgasse 9, 1010 Wien, Austria
ZVR: 327279890 | DVR: 1055887

OVE - Testing & Certification
Kahlenberger Str. 2A, 1190 Wien, Austria
Phone: +43 1 370 58 06
www.ove.at



Page 1 of 4

ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: **25214-001-03**

Valid from: 2016 07 21
until: 2018 07 21

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Company: **Mersen France SB SAS**
15 Rue Jacques de Vaucanson
69720 Saint Bonnet de Mure
France

Product: **Switch-disconnector-fuse**

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the applicant holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s): **2.03.01010.1.0/D0 LINO CUR**

Österreichischer Verband für Elektrotechnik
Head of Testing & Certification

Digitally signed by W. Martin
Email=w.martin@ove.at

Dipl.-Ing. W. Martin

Vienna, 2016 04 29



OVE - Testing & Certification

Accredited by the Federal Ministry of Science, Research and Economy as Certification Body for products within the scope as given in the official decree and published under www.en.bmwf.gv.at/accreditation





Österreichischer Verband
für Elektrotechnik

Certificate No.: 25214-001-03
Date: 2016 04 29
Page 2 of 4

Manufacturer:

Mersen France SB SAS
15 Rue Jacques de Vaucanson
69720 Saint Bonnet de Mure
France

Factory location(s):

Mersen France SB SAS
15 Rue Jacques de Vaucanson
69720 Saint Bonnet de Mure
France



Tested and certified according to:

OVE/ÖNORM EN 60947-1:2011-11-01
OVE/ÖNORM EN 60947-3:2013-01-01

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity with the listed standards as defined by the EU Low-Voltage Directive 2014/35/EU.

Product: Switch-disconnector-fuse

Type designation:
Rating:

Trademark:

05861.020000
Rated voltage: AC 230/400 V
Rated current: 20 A
1P
AC22B, IP20

MERSEN

05861.025000
Rated voltage: AC 230/400 V
Rated current: 25 A
1P
AC22B, IP20

MERSEN

05861.035000
Rated voltage: AC 230/400 V
Rated current: 35 A
1P
AC22B, IP20

MERSEN

OVE - Testing & Certification

Accredited by the Federal Ministry of Science, Research and Economy as Certification Body for products within the scope as given in the official decree and published under www.en.bmwfiv.gv.at/accreditation





05861.050000 Rated voltage: AC 230/400 V Rated current: 50 A 1P AC22B, IP20	MERSEN
05861.063000 Rated voltage: AC 230/400 V Rated current: 63 A 1P AC22B, IP20	MERSEN
05862.020000 Rated voltage: AC 400 V Rated current: 20 A 2P AC22B, IP20	MERSEN
05862.025000 Rated voltage: AC 400 V Rated current: 25 A 2P AC22B, IP20	MERSEN
05862.035000 Rated voltage: AC 400 V Rated current: 35 A 2P AC22B, IP20	MERSEN
05862.050000 Rated voltage: AC 400 V Rated current: 50 A 2P AC22B, IP20	MERSEN
05862.063000 Rated voltage: AC 400 V Rated current: 63 A 2P AC22B, IP20	MERSEN
05863.020000 Rated voltage: AC 400 V Rated current: 20 A 3P AC22B, IP20	MERSEN
05863.025000 Rated voltage: AC 400 V Rated current: 25 A 3P AC22B, IP20	MERSEN

OVE - Testing & Certification

Accredited by the Federal Ministry of Science, Research and Economy as Certification Body for products within the scope as given in the official decree and published under www.en.bmwfw.gv.at/accreditation





05863.035000 Rated voltage: AC 400 V Rated current: 35 A 3P AC22B, IP20	MERSEN
05863.050000 Rated voltage: AC 400 V Rated current: 50 A 3P AC22B, IP20	MERSEN
05863.063000 Rated voltage: AC 400 V Rated current: 63 A 3P AC22B, IP20	MERSEN
05861.063100 Rated voltage: AC 230 V Rated current: 63 A 1P+N AC22B, IP20	MERSEN
05863.063100 Rated voltage: AC 400 V Rated current: 63 A 3P+N AC22B, IP20	MERSEN
